



TOWN OF JAMESTOWN

SEWER SPILLS – 2009

Date	Location	Amount (gals.)	Cause	Known Environmental Impacts	Verbal Notification (Date & Person)	Corrective Action Taken / Planned
01/08/09	404 E. Main St.	300	Grease and debris in pipe	No adverse impacts observed	Steve Mauney (WSRO) on 01-08-09 at 4:45 PM	Pipe cleaned & debris removed. Public notification of grease policy through town website.
11/28 to 11/29/09	100 Jamestown Oaks Dr.	37,500	Pipe failure	No adverse impacts observed	Chris Tant Emergency Management (Raleigh) on 11-29-09 at 10:18 AM	24" concrete pipe collapsed. Pipe removed and replaced. Town is continuing video inspection of system.