

Settled 1752
JAMESTOWN
NORTH CAROLINA

January 2, 2018

**System Performance Annual Report
North Carolina Division of Water Quality
1617 Mail Service Center
Raleigh, NC 27699-1617**

**RE: 2017 Sewer Performance Annual
Report for the Town of Jamestown
WQCS 00314**


Gentlemen:

Enclosed please find the 2017 Sewer Performance Annual Report for the Town of Jamestown. The Town had one sewer spill of 800 gallons on May 5, 2017 (NCDEQ Incident Number 201700823). It took staff nearly seven hours to stop this overflow as we had equipment that became lodged in the submerged manholes. We hope to have no sewer spills for 2018.

The Town of Jamestown collects wastewater and discharges into the City of High Point wastewater collection system where treatment occurs at the Eastside WWTF.

This letter is available on the Town's website (www.jamestown-nc.gov) and at Town Hall located at 301 East Main Street. Public notices are provided in utility billings. This report is accurate and complete to the best of my knowledge. Please feel free to contact me at 336-454-1138 should you have any questions or concerns.

Respectfully,


Paul R. Blanchard, PE
Director of Public Services

File



TOWN OF JAMESTOWN

SEWER SPILLS - 2017

Date	Location	Amount (gals.)	Cause	Known Environmental Impacts	Verbal Notification (Date & Person)	Corrective Action Taken / Planned
05/05/17	Manhole HL009 at 108 Oakdale Road	800	Partial pipe collapse, grease & debris in the line	No adverse impacts observed	Joe Brennan of NC Dept. of Emergency Management on 5/6/17.	The blockage was removed by jetting/flushing and flow resumed. The damaged portion of the line segment was later replaced.